

# Certificate

## Hygiene conformity test

**Tested type series**                    **ZHK 2000**

**Device type**                            air-handling unit

**Manufacturer**                        Euroclima AG - SpA, J.G. Mahl Str. 1b - Via J.G. Mahl 1b, I-39031 Bruneck - Brunico, Italien

**Date and place of test**                29. - 30.09.2009, Euroclima AG – SpA, Arnbach 88, A-9920 Sillian and J.G. Mahl Str. 1b, I-39031 Bruneck

**Test criterion**                         Hygiene requirements of the following standards:

<b>Standard climatisation</b>		<b>Hospitals</b>	
VDI 6022, Blatt 1 (04/2006)	<input checked="" type="checkbox"/>	DIN 1946-4 (12/2008)	<input checked="" type="checkbox"/>
SWKI VA104-01 (04/2006)	<input checked="" type="checkbox"/>	SWKI 99-3 (03/2004)	<input checked="" type="checkbox"/>
VDI 3803 (10/2002)	<input checked="" type="checkbox"/>	ÖNORM H 6020 (02/2007)	<input checked="" type="checkbox"/>
ÖNORM H 6021 (09/2003)	<input checked="" type="checkbox"/>		
DIN EN 13779 (09/2007)	<input checked="" type="checkbox"/>		

**Test result**                              Hygiene conformity is

not confirmed.  
 confirmed with requirements.  
 confirmed.

**Validity period**                        3 years: 09.2009 - 09.2012

**Registration number**                 HKP/I/084-1/8/0909/0912/MZ



Dr.-Ing. M. Möritz

Berlin, 30.04.2010

Within the scope of the hygiene conformity test, the hygiene-relevant requirements of the regulations listed under the "test criteria" and marked with a "✓" were tested. Requirements referred to in other regulations were not tested. The hygiene conformity test does not include toxicological tests or assessments of the materials used in the tested equipment series.