

**AMT DER NIEDERÖSTERREICHISCHEN LANDESREGIERUNG**  
**ABTEILUNG BD4**  
**SICHERHEITSTECHNIK IM GESUNDHEITSWESEN**

Postanschrift 3109 St. Pölten, Landhausplatz 1  
Tel.:0043 2742 9005 14262,e-mail:franz.woesch@noel.gv.at

20C 438/11w

St. Pölten, 29.11.2011

**Official Notice**  
**Safety and hygienic examination of the**  
**central air handling units of manufacturer Euroclima**  
**corporate brand / type: Euroclima / ZHK 2000 and ZHK T-TWO**  
**for use in health care**

**1. General**

Review body	Amt der NÖ Landesregierung department BD4 , 3109 St. Pölten	
Client	Euroclima Apparatebau GmbH Arnbach 88 A-9920 Sillian, Austria	Euroclima AG/Spa St. Lorenzner Straße I-39031 Bruneck, Italy
Official expert	Ing. Franz Wösch	

**2. Scope**

Creating an examination (hygiene and safety report) on central air handling units of the Type / Series ZHK 2000 and ZHK T-TWO.

**3. Standards**

The following standards, expertises and reports were used for evaluation:  
Test report by the expert bureau Michalitsch referring to the following standards: Austrian Standard ÖNORM H 6020, EN 1886 and EN 13053 (in each case as amended).

**4. Test Result**

The test report states that central air handling units Euroclima / ZHK 2000 and ZHK T-TWO correspond to the standards specified in item 3 .

Therefore there are no health concerns against the use of central air handling units of the Euroclima / ZHK 2000 and ZHK T-TWO series.

The test result is valid for a limited period up to and including 11 / 2016.

If the series is changed in structural and functional respect, a review by the official expert will be necessary.

The test report has to be adapted, if fundamental changes to relevant standards are published and if the validity of the relevant test reports taken as a basis expires.

St.Pölten, 29.11.2011

