


Hygiene-Institut des Ruhrgebiets

Institut für Umwelthygiene und Toxikologie

Direktor: Prof. Dr. rer. nat. L. Dunemann

Hygiene-Institut, UMWELT Postfach 10 12 55 · 45812 Gelsenkirchen



Rotthauer Str. 21
45879 Gelsenkirchen

Telefon (0209) 9242-0
Telefax (0209) 9242-222
Internet www.hyg.de

Unser Zeichen: W-291490e-17-WD
Ansprechpartner: F. Wedke B. Eng.

Certificate

Hygiene – Type Examination

Test institute: Hygiene Institut des Ruhrgebiets
Institut für Umwelthygiene und Toxikologie
Rotthauer Straße 21
49879 Gelsenkirchen

Test object: HVAC system „ZHK“

Manufacturer: Euroclima AG - SpA
J.G. Mahl Straße 1b
I-39031 Bruneck

Basis of the examination:

- ✓ VDI 6022, Blatt 1 (07/2011)
- ✓ SWKI VA104-01 (04/2006)
- ✓ DIN 1946, Teil 4 (12/2008)
- ✓ ÖNORM H 6021 (09/2003)
- ✓ ÖNORM H 6020 (02/2007)



Validity period: 5 years 11/2017 – 11/2022

Test report: W-223080-12-Ho

In conclusion it can be stated that the examined HVAC system „ZHK“, as specified in the test report W-223080-12-Ho, is in compliance with the above mentioned regulations.

(Priv.-Doz. Dr. G.-J. Tuschewitzki)
Head of the Department of Water
Hygiene and Environmental
Microbiology

(F. Wedke B. Eng.)
Administrator of Air Conditioning technology
Department of Water
Hygiene and Environmental Microbiology

issued 13.11.2017, Gelsenkirchen

Within the framework of the hygiene-type examination the hygiene-relevant requirements of the above mentioned regulations were examined. Requirements of other regulations that refer to the above mentioned regulations were not part of the examination. Additionally, the type test does not include a toxicological or sensory testing of the introduced materials.

Träger des Instituts: Verein zur Bekämpfung der Volkskrankheiten im Ruhrkohlengebiet e.V., Gelsenkirchen, Vereinsregister: VR 519 Amtsgericht Gelsenkirchen
USt-ID: DE125018356, Vorstand: Henriette Reker (Vorsitzende), Prof. Dr. Jürgen Kretschmann, Dr. Emanuel Grün, Volker Vohmann, Prof. Dr. Lothar Dunemann