


Hygiene-Institut des Ruhrgebiets

Institut für Umwelthygiene und Toxikologie
Direktor: Prof. Dr. rer. nat. L. Dunemann

Hygiene-Institut, UMWELT Postfach 10 12 55 · 45812 Gelsenkirchen



Rotthaus Str. 21
45879 Gelsenkirchen

Telefon (0209) 9242-0
Telefax (0209) 9242-222
Internet www.hyg.de

Unser Zeichen: W-291492e-17-WD
Ansprechpartner: F. Wedke B. Eng.

Certificate

Hygiene – Type Examination

Test institute: Hygiene Institut des Ruhrgebiets
Institut für Umwelthygiene und Toxikologie
Rotthauser Straße 21
49879 Gelsenkirchen

Test object: HVAC system „ZHK“

Manufacturer: Euroclima Middle East Central Air Conditioning
Equipment Manufacturing L.L.C
P.O.Box: 119870
Dubai Investment Park – I
598-1211, Dubai
United Arab Emirates

Basis of the examination:

- ✓ VDI 6022, Blatt 1 (07/2011)
- ✓ SWKI VA104-01 (04/2006)
- ✓ DIN 1946, Teil 4 (12/2008)
- ✓ ÖNORM H 6021 (09/2003)
- ✓ ÖNORM H 6020 (02/2007)

Validity period: 5 years 11/2017 – 11/2022

Test report: W-223080-12-Ho



In conclusion it can be stated that the examined HVAC system „ZHK“, as specified in the test report W-223080-12-Ho, is in compliance with the above mentioned regulations.

(Priv.-Doz. Dr. G.-J. Tuschewitzki)
Head of the Department of Water
Hygiene and Environmental
Microbiology

(F. Wedke B. Eng.)
Administrator of Air Conditioning technology
Department of Water
Hygiene and Environmental Microbiology

issued 13.11.2017, Gelsenkirchen

Within the framework of the hygiene-type examination the hygiene-relevant requirements of the above mentioned regulations were examined. Requirements of other regulations that refer to the above mentioned regulations were not part of the examination. Additionally, the type test does not include a toxicological or sensory testing of the introduced materials.